

SCHEDULE OF FMH

MH No.	C L	I L	REMARKS
F 1	39.800	36.900	
2	39.950	37.168	
3	40.200	37.795	
4	40.400	37.955	
5	40.250	38.115	
6	40.600	38.975	
7	40.250	39.650	tumble to MH.5
8	40.000	37.162	
9	40.100	37.706	
10	40.050	37.909	
11	40.150	38.066	
12	40.100	38.906	
13	40.100	38.192	

ALL DRAINPIPES UPVC ON GRANULAR BED CONCRETE PROTECTION WHERE LESS THAN 1200 COVER UNDER ROADS

MANHOLES NOT EXCEEDING 900 DEEP IN UPVC

MANHOLES EXCEEDING 900 DEEP IN PRECAST CONCRETE RECTANGULAR SECTIONS

CONNECTIONS TO ROAD GULLIES 150 DIAM UPVC

ALL LATERALS 100 DIAM UPVC

SUPPORT TO BE PROVIDED TO ALL DRAINS UNDER BUILDINGS

ALL RAINWATER SOAKAWAYS 900 DIAM. 1500 BELOW DRAINPIPE INLET CONSTRUCTED IN 225 DRY STEINED BRICKWORK BUILT OFF CONCRETE BASE WITH R CONCRETE COVER SET 300 BELOW FINISHED GROUND LEVEL

RWS TYPE A MIN. CAPACITY 1.5 CU.M.
 B MIN. CAPACITY 3.3 CU.M.
 C MIN. CAPACITY 4.3 CU.M.

OTHERS - SUBJECT TO AGREEMENT ON SITE

Exact positions of all ducts, mains, meters etc. to be agreed with appropriate authorities.

Setting out of all buildings to be agreed on site with Local Authority.